FIRE TEST QUALIFICATION CERTIFICATE





Manufactured by: Test date: Item:

Size: Class:

In accordance with drawing no: Further details see A⁺ RTD Report no:

TM Filters B.V. 25 May 2018 Three-Way Floating Ball Valve 2 Inch 150 Lbs

150 Lbs EN-DE-0054-Rev.0 131544/001-R001

This certificate must be read in conjunction with the full Applus RTD Meettechniek test report. The details are mentioned in the list above. The valve was tested by Applus RTD Meettechniek at their valve testing facility in Kapelle, the Netherlands. The result has been recorded as APPROVED, according to the minimum performance requirements stated in specification:

API Standard 607, Seventh Edition, June 2016

Qualification of other size of valve

Other Valves Qualified by DN

| Size of valve to be tested (DN) | Other valve sizes qualified (DN) |
|---------------------------------|----------------------------------|
| 50 | 50 and below; 65; 80; 100 |

Other Valves Qualified by NPS

| Size of valve to be tested (NPS) | Other valve sizes qualified (NPS) |
|----------------------------------|-----------------------------------|
| 2 | 2 and below; 2½; 3; 4 |

Other Valves Qualified by Class

| cure raires quantitally state | | | |
|-------------------------------|-----------------------------|---------------------------------------|--|
| | Valve tested (Class Rating) | Other valves qualified (Class Rating) | |
| | 150 | 150: 300 | |

Tested by:

Name

Mr. F.L. Gillissen

Date

25 May 2018

Witnessed by:

Name

Mr. S. Rasheed

Date

25 May 2018